



No.F6/DFS/MS/School/SZ/2023/354

Dated: 25/05/2023

FIRE SAFETY CERTIFICATE

Certified that the **Panchsheel Public School located at H-Block, Jaitpur, Badarpur, New Delhi-44**, comprised of **Ground + 02 upper floors** was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/166 dated 29.04.2020. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 22.05.2023 in the presence of Mrs. Jaya Joshi (Head Mistress) and found that the school building has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-362 dated-17.01.2005 issued by the Directorate of Education and the building (**Ground + 2 upper floors**) is fit for occupancy of Group B "**Educational Building**" with effect from 25/05/2023 renewed for a period of three years, subject to conditions printed below.

Issued on 25/05/2023 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, Panchsheel Public School located at H-Block, Jaitpur, Badarpur, New Delhi-44.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.